

#### **CODE NUMBER**

3981524

#### **DESCRIPTION**

1.6 gpf, Rough Brass Finish, Single Flush, Solenoid-Operated with Modular Plug, Regal® Concealed Manual Water Closet Flushometer.

#### DETAILS

Flush Volume: 1.6 gpf (6.0 Lpf)Finish: Rough Brass (RB)

• Valve: Diaphragm

• Valve Body Material: Semi-red Brass

Fixture Type: Water ClosetFixture Connection: Not Included

• Supply Pipe: 1" (25mm)

#### **FEATURES**

- Vacuum Breaker
- Non-Hold-Open Integral Solenoid Operator, Fixed Metering Bypass and No External Volume Adjustment to Ensure Water Conservation
- Stop Seat and Vacuum Breaker molded from PERMEX® Rubber Compound for Chloramine Resistance
- Water-Resistant (NEMA 4) Courtesy Flush® Override Button
- 1" I.P.S. Wheel Handle Bak-Chek® Angle Stop



## **COMPLIANCES & CERTIFICATIONS**







(ADA Compliant, cUPC Certified, BAA Compliant)

### RECOMMENDED SPECIFICATION

Valve Body, Cover, Tailpiece and Control Stop shall be in conformance with ASTM Alloy Classification for Semi-Red Brass. Valve shall be in compliance with the applicable sections of ASSE 1037 and ANSI/ASME 112.19.2.

### **ELECTRICAL SPECIFICATIONS**

- Solenoid Operator: 24 VAC
- Transformers:
  - 0345154
  - 0345999

# **VALVE OPERATING PRESSURE (FLOWING)**

15–80 PSI (103–552 kPa). Specific fixtures may require greater minimum flowing pressure - consult manufacturer requirements.

## **DOWNLOADS**

- Control Stop Repair and Maintenance Guide
- Flush Connections Flanges Repair and Maintenance Guide
- Tail Piece Repair and Maintenance Guide
- Regal Flushometers Repair and Maintenance Guide
- Concealed Flushometers Repair and Maintenance Guide
- Additional Downloads

# **NOTES**

All information contained within this document subject to change without notice.

Looking for other variations of the REGAL 150 ES product? View the general spec sheet with all options.

Find a compatible urinal for this flushometer.
Find a compatible water closet for this flushometer.

Phone: 800.982.5839 • Fax: 800.447.8329 • sloan.com



# **ROUGH-IN**

